

Amendments to 2018 International Plumbing Code.

The following amendments to the plumbing code adopted in section 5-87 are hereby adopted:

- (1) Following Section 710.2, a new Section 710.3 Underground drainage shall be added which shall read as follows: Any portion of the drainage system installed underground or below a slab shall not be less than 2 inches (51 mm) in diameter.
- (2) Section 904.2, Stack required is amended by inserting the following language after the first sentence: "In no case shall the main vent stack be less than three inches in diameter."
- (3) Section Table 403.1, Minimum number of required plumbing fixtures. Add the following exception: "Where approved by the Building Official, a service sink shall not be required in occupancies less than 2,000 square feet where more than fifty percent of the floor area is carpeted. Occupancies that generate medical waste or other hazardous byproducts shall not be included in this exception."